



BILANS MOCY					
Lp.	Obwód	Ilość odbiorników	P1 (W) moc zainstalowana	kj współczynnik jednoczesności	P2 (W) moc zapotrzebowana
1	FATO1	10	20	1,0	200
2	FATO2	10	20	1,0	200
3	TLOF	4	14	1,0	56
4	ŚWIATŁA NAPR.	6	14	1,0	84
5	RL	1	300	1,0	300
6	PS-02	1	30	1,0	30
7	PS-02 TOP	1	30	1,0	30
8	WKW	1	84	1,0	84
9	HAP1	1	500	1,0	500
10	NAŚWIETLACZE	16	90	1,0	1440
11	GSL-RC	1	200	1,0	200
12	WKW1	1	84	1,0	84
13	OSW. PRZESZ.	13	35	1,0	455
			RAZEM		3663

[illegible]