

Załącznik nr 2

Tabele regulacyjne instalacji odbiorczych

	parametry kotłowe		co		wzp		ctz		cts		cwu	
T-zew	T-zas	T-pow	T-zas	T-pow	T-zas	T-pow	T-zas	T-pow	T-zas	T-pow	T-zas	T-cyrk
stopnie Celsjusza												
-18	116	70	75	55	112	70	85	65	90	70		
-17	114	70	74	54	110	70	82	63	90	70		
-16	112	70	72	53	108	70	80	61	90	70		
-15	110	70	70	52	106	70	78	60	90	70		
-14	108	70	68	51	104	70	76	59	90	70		
-13	106	70	67	50	102	70	74	57	90	70		
-12	104	70	66	49	100	70	72	55	90	70		
-11	102	70	65	48	99	70	70	53	90	70		
-10	100	70	64	47	98	70	68	51	90	70		
-9	99	70	63	46	97	70	67	50	90	70		
-8	98	70	61	45	96	70	66	49	90	70		
-7	97	70	59	44	95	70	65	48	90	70		
-6	96	70	57	43	94	70	64	47	90	70		
-5	95	70	56	41	93	70	63	46	90	70		
-4	94	70	55	39	92	70	61	45	90	70		
-3	93	70	54	37	91	70	59	44	90	70		
-2	92	70	53	36	90	70	57	43	90	70		
-1	91	70	52	36	90	70	56	43	90	70		
0	90	70	51	35	89	70	55	43	90	70		
1	90	70	50	34	89	70	54	43	90	70		
2	89	70	49	34	89	70	53	43	80	60		
3	89	70	48	33	88	70	52	42	80	60		
4	89	70	47	33	87	70	51	42	80	60		
5	88	70	46	32	85	70	50	41	80	60		
6	87	68	45	32	84	68	50	41	80	60		
7	85	68	44	32	83	68	50	41	80	60		
8	84	68	43	31	82	68	49	40	80	60		
9	83	68	41	30	81	68	49	40	80	60		
10	82	68	39	29	81	68	48	40	80	60		
11	81	68	37	29	80	68	48	40	75	55		
12	81	68	36	28	80	68	48	40	75	55		
...												