


Wymiary otworu w stropie


Wymiary gotowego szybu

Otwór na drzwi z ościeżnicą		
Przystanek	Szerokość	Wysokość
A 1	1530	2250
B 0	1630	2250
B 2	1630	2250



B2 (1:5)




B0 (1:5)



A1 (1:5)



Incoming power supply is connected at landing.  
For wiring and power supply, refer to the unit's wiring diagrams.  
Ceiling shaft lighting, is independent from the power cable and pulled back into the trench's upper part. Shaft lighting > 50 lux.  
**NOTE!** An effective emergency telephone is required for approved inspection.  
The purchaser is responsible for an active phone line being present prior to the lift installation.  
The incoming telephone line is connected to C1low (TELE). Refer to wiring diagram.  
The emergency signal device is powered by the lift's own battery in the event of a power failure.  
The lift must be equipped with a two-way communication, either via the standard telephone or via the lift telephone, which automatically calls the alarm control center or the like.  
**NOTE!** A lift featuring a frequency converter cannot be directly connected to a RCD.  
**NOTE!** The platform lift shall be connected to a dedicated power supply conforming with EN 60204-1:2018, terminating at a main switch and fuse or overload with a means to lock it in the 'off' position or disconnected state



50 mm podszybie, powinno być płaskie, tolerancja +10 mm, - 0mm



DETALE PLATFORMY.

rys. A-7

Zatwierdzone przez producenta:

EOS ID  
L00366307  
Oferta  
Zamówieni

Rysunek schematyczny  
A 5000 - 1100\*1467  
Wymiary otworów  
43/MD/03/2022

European view placement:



Gen. Tolerances  
SS-ISO 27681-1 m

Data  
2022-04-02  
14:12

Arkusze  
2 of 7  
Skala:  
A3, 1:55